वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/11/2026

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done(3 times)	08:15:00	13:00:00	
2	OHP	TBS on CO-21	LT not taking place	PCRD tension acted.Released and guide problem found	08:15:00	08:25:00	Informed to mechanical
3	CHP	R-1 on CC-36	Yard Interlock cage stuck	Cage and probe replaced and tested okay	07:00:00	07:30:00	NO delay
4	CHP	SCR-09 on CC-104	Lt not taking place	PCRD tension acted.Released and tested okay	08:30:00	08:40:00	
5	CHP	SCR-3 on CC-106	B/C not running	MPD tripped.Reset done	09:10:00	09:20:00	