



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/07/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-26	Luffing not taking place	OLR acted.Reset done	18:34:00	18:50:00	
2	OHP	BRC on CO-32	B/W's not running	Oil level low.	18:50:00	19:05:00	Informed to mechanical
3	CHP	CC-52	MPD tripped	Reset done	20:30:00	20:40:00	
4	CHP	CC-33 SCR-2	LT not taking place	PCRD drum sensor acted.Reset done	16:35:00	16:45:00	
5	CHP	CC-33 SCR-2	B/W not running	Drive tripped.Reset done	17:05:00	17:20:00	
6	CHP	CC-37 SCR-3	B/C not running	OLR acted.Reset done	18:15:00	18:25:00	
7	CHP	CC-31 SCR-1	Slewing not taking place	Drive tripped.Reset done	21:30:00	21:40:00	