



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/07/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED (2TIMES)	RESET DONE	06:45:00 08:25:00	06:50:00 08:35:00	
2	OHP	WOBR ON CO-25	LT NOT TAKING PLACE FOUND PCRD O/T ACTED	RELEASED THAN OK	08:25:00	08:40:00	
3	OHP	CR-1	TRIP ON OVER CURRENT FAULT (DUE TO JAMMING)	RESET DONE AFTER CLEAR THE JAMMING	12:10:00	12:25:00	
4	CHP	CC-52	MPD TRIP (2TIMES)	RESET DONE	12:05:00	13:10:00	
5	CHP	CC-107	OLR ACTED	RESET DONE	09:10:00	09:15:00	
6	CHP	CC-213 SCR-9	REPORTED B/C NOT RUNNING DUE TO MATERIAL SELECTION PROBLEM	CLEARED THAN OK	10:50:00	11:10:00	
7	CHP	CC-32 SCR-4	REPORTED B/C NOT RUNNING SELECTION MODE PROBLEM	KEPT PROPERLY THAN OK	12:30:00	12:55:00	
8	WT	CP-1,CP-2	COMMUNICATION PROBLEM	PLC SUPPLY RE-CYCLED THAN OK	13:35:00	13:45:00	