



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/08/2026

Incharge(s): G Eswara Rao

Shift: C

| Sl No | Area | Equipment     | Problem                 | Action      | From     | To       | Remarks |
|-------|------|---------------|-------------------------|-------------|----------|----------|---------|
| 1     | OHP  | WOBR ON CO 6A | FAULT RESET PB STUCKUP/ | PB REPLACED | 01:10:00 | 01:25:00 |         |
| 2     | OHP  | CO 29         | TRIPPED ON OLR          | RESET DONE  | 03:20:00 | 03:30:00 |         |
| 3     | OHP  | CO 25         | TRIPPED ON OLR          | RESET DONE  | 04:50:00 | 05:00:00 |         |
| 4     | CHP  | CC 131        | TRIPPED ON OLR          | RESET DONE  | 01:15:00 | 01:20:00 |         |
| 5     | CHP  | SCR 7 ON CC40 | MPD TRIPPED ON OLR      | RESET DONE  | 02:25:00 | 23:00:00 |         |