



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/09/2026

Area: WT

Equipment	Job
MIS	one 200 W LED installed @ walkway bridge
MIS	C I S F sump pump removed from Coal bed drainage system
CP 4	cleats welding and channel cutting work done for AC fixing
OP 6	D3 stator and one rotor contactor replaced
OP 4	D3 and D4 rotor cable fault rectified
LC 10 A	Panel maintenance done