



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	wobr on co 25	luffing not taking place/olr acted	reset done	10:00:00	10:15:00	
2	OHP	co 25	tripped on olr	reset done	11:20:00	11:30:00	
3	CHP	cc 104	brs acted due to moisture	bypassed for ope.requirement	11:00:00	11:20:00	to be kept in ckt
4	CHP	r1 on cc 111	bc signal missing while reclaiming	zss cage replaced	07:20:00	07:40:00	