



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	03:47:00	03:57:00	
2	OHP	WOBR on co 25	luff not working olr acted	reset	00:15:00	00:30:00	
3	CHP	CC 28	olr acted	reset	22:45:00	22:50:00	
4	CHP	CC 51	mpd tripped	reset	02:45:00	02:50:00	
5	CHP	CC 131	tripped in olr	reset	02:05:00	02:10:00	
6	WT	CP 2	no movement,no power,acb tripped @col no 42-43 ,while reverse going after rake completion	acb made on	00:20:00	00:30:00	