



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/09/2026

Area: CHP

Equipment	Job
CC 202 Gallyary	Lighting ckt problem rectified and improved lighting
VS 1,VF 1	PPM was done
LC 17,Coal complex	Rooms cleaning done
CC 43/44	2 nos 200W fixtures provided
CC 125 Tunnel	6 nos 35W LED fixtures replaced
SCR 8,9,10	Lighting timers kept in auto mode
CC 31,43,SCR 1	PPM was done