वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 12/10/2026

Shift: A

Incharge(s): Lal Singh

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | BRC-32 | LT NOT RUNNING | WRONG COMPLAINT | 11:50:00 | 12:05:00 | |
| 2 | OHP | BRC ON CO-8A | LT NOT WORKING PCRD NOT HEALTHY | PCRD MPCB ADD-ON BLOCK PROBLEM ... BYPASSED | 09:45:00 | 10:40:00 | TO BE REPLACED AND KEPT IN CKT |
| 3 | CHP | CC-37 SCR-3 | LT NOT TAKING PLACE | DRIVE TRIPPED ... RESET DONE | 07:00:00 | 07:10:00 | |
| 4 | CHP | CC-37 SCR-3 | BC NOT RUNNING MPR TRIPPED | RESET DONE | 08:20:00 | 08:30:00 | |
| 5 | CHP | CC-32 | MPD TRIPPED | RESET DONE | 11:15:00 | 11:25:00 | |