वी.एस.पी
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

### ELECTRICAL SHIFT REPORT

Date: 08/11/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|---|---|---|---|---|---|---|---|
| 1 | OHP | vf 10a | olr acted | reset | 12:30:00 | 12:40:00 | |
| 2 | OHP | op5 | no power,i/c tripped @ col no 51 | made on,checked near pusher nothing found | 07:50:00 | 08:00:00 | |
| 3 | OHP | VF2 | mpcb tripped | reset | 13:20:00 | 13:25:00 | |
| 4 | OHP | BRC on co 33 M | LT is not working | checked all ok,wrong complaint | 08:30:00 | 08:45:00 | |
| 5 | OHP | co 26 | olr acted | reset | 12:35:00 | 12:40:00 | |
| 6 | CHP | CC 51 | mpd tripped | reset | 08:35:00 | 08:40:00 | |
| 7 | CHP | CC 131 | olr acted | reset | 10:05:00 | 10:10:00 | |
| 8 | CHP | cc 54 | OLR ACTED | reset | 09:50:00 | 09:55:00 | 2 times |
| 9 | CHP | CC 111 scr 4 | pcrd problem,guide problem | informed mech | 08:00:00 | 08:10:00 | |
| 10 | CHP | CC 32 scr5 | LT not working,emergency Pb acted | released | 10:00:00 | 10:10:00 | |
| 11 | WT | cp 4 | no fwd movement,fwd lmt acted | released | 06:10:00 | 06:20:00 | |
| 12 | WT | OP5 | no power,acb tripped @ col no 90 | made it on,checked pusher no spark observed | 09:25:00 | 09:45:00 | to be checked trolley line |
| 13 | WT | OAF 1A,2A and OC1A | reported red | PLC power recycle done | 09:30:00 | 09:40:00 | to be checked |