RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 07/11/2026

Area: WT

Equipment	Job
LC 9	sump pump ,AUTO ON/OFF circuit provided and kept in circuit
CP 4	Trolley line cable ,R and Y cables jointing and termination done @ col no 58
OP 2	D3 motor removed for gear box repair