RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 07/11/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR acted	Reset	23:00:00	03:30:00	2 times
2	OHP	BRC on CO 8a LT	M2 Trip	Made it on	02:30:00	02:40:00	
3	OHP	TBS on CO 22 Left Luff	OLR acted	Reset	02:55:00	03:05:00	
4	OHP	Scr 1 on CC 31 LT	Drive trip	Reset	05:30:00	05:40:00	
5	CHP	CC 51	OLR acted	Reset	23:55:00	00:00:00	
6	CHP	CO 13 CD	OLR acted	Reset	04:00:00	04:10:00	
7	CHP	CC 203	OLR acted	Reset	03:30:00	03:40:00	