



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/06/2026

Area: CHP

Equipment	Job
RG-2,VF-2 AND VS-2	Panel and motor side PPM done
CC-27A,CC-103,TT ON CC-27A,103	Panels and motors PPM done
CC-25,CC-26	Belt sway switches taken into circuit
Misc	LC-17,LC-18 PLC I/O rack connections tightness checking done
Lighting	For IOSA street lighting control, PLC timer programmed and wired upto CC-217 feeder.
CC-38,43,44,46,107,125 and SCR-5	Running inspection done
CC-41,45,48,49	PPM work done