



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/07/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	23:40:00	01:15:00	3 times
2	OHP	CO 20	BRS acted	Reset	00:55:00	01:05:00	
3	OHP	BRC on CO 30 LT	PCRD O/T acted	Released	02:35:00	02:45:00	
4	OHP	BRC on CO 28	B/C OLR acted	Reset	03:40:00	03:50:00	
5	CHP	S 1 on CC 36	LT M1 Tripped	Reset	23:15:00	23:30:00	
6	CHP	SCR4 on CC 33	LT Rev End Limit Switch not working	Bypassed in I/O Rack	02:30:00	02:50:00	
7	CHP	CC 51	Feeding Conv OLR acted	Reset	00:30:00	05:00:00	5 Times
8	CHP	CC 52	Feeding Conv OLR acted	Reset	00:30:00	05:30:00	4 Times
9	CHP	CC 131	OLR acted	Reset	00:30:00	01:30:00	2Times
10	WT	OT 3	D! Tripped	Reset	22:40:00	01:05:00	2 Times