



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 26/08/2026

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO -20	RBC STOPPING	ZSS CAGE STUCK ... MADE FREE	23:15:00	23:30:00	
2	OHP	BRC ON CO-8A	NO POWER COMPLAINT	POWER OK ... NO OPERATOR	00:00:00	00:15:00	
3	OHP	CO-26	TRIPPED ON OLR	RESET DONE	01:00:00	01:10:00	
4	OHP	WBR ON CO -26	BC STOPPING ON ZSS	PROB FIXING PROBLEM ... FIXED PROPERLY	02:09:00	02:35:00	
5	OHP	CO-29	TRIPPED ON OLR	RESET DONE	02:50:00	03:00:00	
6	CHP	CC-55 CC-114	NO POWER ... LC-19 INCOMER -2 TRIPPED IN LBDS 4	MADE ON	00:00:00	00:40:00	LC-19 INCOMER -2 TRIPPING TO BE CHECKED
7	CHP	CC-115	STOPPED ON ZSS	CHECKED .. NO ELECTRICAL PROBLEM	04:30:00	04:50:00	