



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/05/2026

Area: WT

Equipment	Job
CP-1	TROLLEY LINE INSPECTION DONE AND DEFECTS NOTED
U-15 OP-1	TROLLEY LINE INSPECTION DONE AND PROBLEM RECTIFIED
U-4 OP-8	28 NO OF INSULATORS REPLACED