



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/05/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	03:20:00 05:15:00	03:30:00 05:25:00	
2	OHP	TT1	F/G MPCB TRIP	MADE IT ON	23:50:00	23:55:00	
3	CHP	CC51	FEEDING CONV OLR ACTED	RESET	00:25:00	04:00:00	3 TIMES
4	CHP	CC 52	OLR ACTED	RESET	03:55:00	04:00:00	
5	CHP	CC 107	OLR ACTED	RESET	05:10:00	05:15:00	
6	WT	OP8	LS1, LS2 NOT HEALTHY	BYPASSED	05:30:00	05:40:00	