



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/08/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 49 ON CO20	CHUTE VIBRATOR power mpcb tripped, motor bearing stucked	made it off	04:15:00	04:40:00	to be replaced
2	OHP	co 25	olr acted	reset	00:55:00	01:05:00	
3	OHP	brc on co 30	BC not running, control mcb tripped	made it on	02:40:00	03:00:00	
4	OHP	co 29	olr acted	reset	03:20:00	03:30:00	
5	OHP	TBS on Co 5a	LT not taking place, gear box problem	informed mechanical	05:15:00	05:34:00	
6	CHP	CC 50	ZSS ACTING DUE TO OVER MATERIAL/BELT LOW SPEED	INFORM TO OPE.	02:50:00	03:05:00	
7	CHP	CC 51	MPD TRIPPED ON OLR	RESET DONE	22:30:00	22:40:00	
8	CHP	CC 131	TRIPPED ON OLR	RESET DONE	02:40:00	02:45:00	
9	IOSA	L and T wobbr	Lt not taking place, OT acted	OT released	03:10:00	03:20:00	