RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 24/10/2026

Area: WT

Equipment	Job
MIS	DRIVE BYPASS PROGRAMED AND BYPASS OPTION GIVEN IN SCADA
OP-5	D4 OLD MOTOR REMOVED AND NEW KEPT IN BED
OP-7 TROLLY LINE	23 INSULATORS CHANGED FROM COL. NO 96 TO 46
CP-3	MOTOR AND PANEL SIDE PPM DONE