



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/07/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	CHP	Cc-54	Reported tripped	OLR acted.Reset done	16:29:00 16:37:00 21:32:00	16:33:00 16:40:00 21:35:00	
2	CHP	CC-51A	Reported tripped	OLR acted.Reset done	19:15:00 19:23:00	19:20:00 19:30:00	
3	CHP	CC-131	Reported tripped	OLR acted.Reset done	21:20:00	21:23:00	
4	CHP	CC-29	BSS acted	T/E switch damaged.Bypassed	17:30:00	17:40:00	
5	CHP	CC-28	F/G tripped	MPCB tripped.Made on	14:30:00	14:40:00	
6	CHP	Cc-106 SCR-9	B/C not running	PC acted.Released and tested okay	14:45:00	14:56:00	
7	CHP	Cc-106 SCR-9	B/C not running	Signal missing.LT done and tested okay	18:50:00	19:05:00	
8	CHP	Cc-33 SCR-2	B/W not running	Drive tripped.Reset done	19:10:00	19:23:00	