



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/06/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CONVEYORS RED	POWER DIP CAME	RESET	19:20:00	19:40:00	
2	CHP	SCR 5 ON CC 38	LT TRACK JAMMING	INFORMED TO OPRN	14:30:00 19:20:00	14:45:00 19:50:00	
3	CHP	SCR 7 ON CC 40	LUFF OLR ACTED	RESET	20:20:00	20:30:00	
4	CHP	CC 54	OLR ACTED	RESET	19:15:00	20:50:00	3 TIMES
5	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	20:40:00	20:50:00	