



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/06/2026

Incharge(s): Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-5A	LT M2 TRIPPED	RESET DONE	14:20:00	14:30:00	
2	OHP	CO-34	BRS NOT HEALTHY	FUSE PROBLEM ... REPLACED	17:00:00	17:30:00	
3	OHP	CO-26	TRIPPED ON OLR	RESET DONE	18:30:00	18:35:00	
4	OHP	WBR ON CO-29	LUFF TRIPPED ON OLR	RESET DONE	18:45:00	19:00:00	
5	OHP	BRC ON CO-28	BC TRIPPED ON OL	RESET DONE	19:55:00	20:10:00	
6	CHP	CC-51	MPD TRIPPED	RESET DONE	16:40:00	16:45:00	
7	CHP	CC-52	NOT HEALTHY ... EM PB ACTED	RELEASED	16:20:00	16:30:00	
8	CHP	cc-40	luff down limit bypass	as per operation request	16:05:00	16:15:00	
9	CHP	cc-106 scr -9	ht power tripping in lc-2	checking going on	21:00:00	22:00:00	