



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/08/2026

Area: CHP

Equipment	Job
CC 7	Motor replaced and trail run was taken
RG 2,VS 2,VF 2	PPM was done
JH Hoists	Reclaiming stream all hoists maintenance was done
LC	Door locks chain welding work under progress
LC 17,CM 19	Rooms cleaning done
SCR 5	HT cable old joint wrapper replaced by DNW
SCR 5	6 nos 35W LED fixtures replaced and improved lighting
CC 125,126,R 1	PPM was done