



वी.एस.पी  
VSP

RASHTRIYA ISPAT NIGAM LIMITED  
VISAKHAPATNAM STEEL PLANT  
RAW MATERIAL HANDLING PLANT  
ELECTRICAL GENERAL SHIFT REPORT

Date: 21/05/2026

Area: CHP

| Equipment        | Job                                                                                                    |
|------------------|--------------------------------------------------------------------------------------------------------|
| CC 21/22 gallery | Lighting improved                                                                                      |
| JH C 3           | Hoist panels maintenance was done                                                                      |
| CHP              | Spare motor details collected and noted                                                                |
| CM 18            | Old PLC panels components removed                                                                      |
| CM 18            | Rooms cleaning done                                                                                    |
| R 1              | B/W oil pump replaced and trail run was taken. MPCB replaced PLC and control desk maintenance was done |
| CC 43/44         | CC 38 point Tunnel blower fan kept running                                                             |
| CC 47,50, 132    | PPM was done                                                                                           |
| CC 53            | Spare motor shifted up to bed                                                                          |
| CC 52,CC 130     | Chute vibrators cables laid and manual operation given                                                 |