



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/08/2026

Shift: A

Incharge(s): Nagendra Midde

| Sl No | Area | Equipment | Problem        | Action                                                    | From     | To       | Remarks |
|-------|------|-----------|----------------|-----------------------------------------------------------|----------|----------|---------|
| 1     | CHP  | SCR 6     | Slew problem   | Material jamming cleared                                  | 12:50:00 | 13:00:00 |         |
| 2     | CHP  | CC 54     | OLR acted      | Reset                                                     | 10:20:00 | 10:30:00 |         |
| 3     | WT   | OP-7      | FWD not moving | Tipper clamp limits switch MCB tripped in PLC panel,Reset | 11:01:00 | 11:10:00 |         |