



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/07/2026

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 21	cjd acting/malfunctioning	bypassed at relay	15:45:00	16:00:00	KEPT IN CKT AT 21.30PM
2	OHP	TT 2 ON CO 15.	LT NOT TAKING PLACE/MPCB TRIPPED	MPCB MADE ON	19:30:00	20:00:00	
3	OHP	co 111	tripped on olr	reset done	21:50:00	21:55:00	
4	OHP	co 26	tripped on olr	reset done	21:20:00	21:30:00	
5	CHP	CC 47	ZSS ACTING/PROBE AND CAGE CHECKED .NO PROBLEM FOUND	GIVEN CLEARENCE	16:55:00	17:05:00	
6	CHP	CC 32	MPD TRIPPED ON OLR	RESET DONE	20:30:00	20:35:00	
7	WT	OT 1	F/R NOT TAKING PLACE/D2 TRIPPED ON OLR	RESET DONE	16:20:00	16:30:00	