RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 11/11/2026

Area: WT

Equipment	Job
OP 2	Anti collision sensor checked and kept in circuit
OP 2	D3 motor placed,alignment ,testing done kept in circuit
OP 4	Trolley line inspection done
OT 4	Hydraulic pump 1 Motor removed and re fixed after mech.work
CT-Exast Fan	checked found Motor is OK, and cable having earth fault