



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/08/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	OLR ACTED (2TIMES)	RESET DONE	00:05:00 05:30:00	00:15:00 05:40:00	
2	OHP	TBS ON CO-20	REPORTED L/BOOM STOPPING ON ZSS CHECKED AND FOUND NO PROBLEM	WRONG COMPLAINT	00:55:00	01:10:00	
3	CHP	TT ON CC-28	F/G MPCB TRIP	MADE ON	00:35:00	00:40:00	
4	CHP	CC-52	MPD TRIP (FEEDING CONVEYOR STOP)	RESET DONE	02:20:00	02:25:00	
5	CHP	CC-112 SCR-8	REPORTED B/C NOT RUNNING FOUND ZSS CAGE STUCK UP WITH COAL PICK	REMOVED COAL PICK THAN OK	02:30:00	02:45:00	
6	CHP	CC-31 SCR-1	LT DRIVE TRIP (OVN) FAULT	RESET DONE	05:35:00	05:50:00	
7	IOSA	L AND T WOBR	REPORTED SLEW NOT WORKING	LUFFING UP DONE THAN SLEW WORKING	02:25:00	02:50:00	