



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/09/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	OLR acted	Reset	04:20:00	04:25:00	
2	OHP	CO 26	OLR acted	Reset	23:05:00	04:20:00	3 tims
3	OHP	CO 33m	OLR acted	Reset	04:40:00	04:50:00	
4	OHP	CO 29	OLR acted	Reset	05:25:00	05:30:00	
5	OHP	CO 10a	OLR acted	Reset	04:40:00	04:50:00	
6	OHP	CO 58	OLR acted	Reset	23:00:00	23:10:00	
7	OHP	CO 5 E/S	Loose connection inside pb station	Tightened Then ok	00:00:00	00:10:00	
8	OHP	WBR on CO 6a	Luff Control MCB off	Made it on	01:50:00	02:00:00	
9	OHP	WBR on CO 29 LT	M# olr acted	Reset	04:35:00	04:50:00	
10	OHP	WBr on CO 25 LT	Water Went Inside PCRD motor and Tripping	Loop Given and Power Kept off	02:10:00	02:40:00	TO be checked
11	OHP	SCR 6 ON cc 38 B/C	C/S insulator got wet and	not resetting after cleaning Bypassed	05:30:00	05:45:00	
12	CHP	CC 51 A	OLR acted	Reset	03:15:00	03:20:00	
13	CHP	SCR 1 on CC 31 B/C	Common High Fuse Blown	Replaced	03:15:00	03:30:00	
14	CHP	CC 29	Control cable loose in sliding contactors	Tightened	00:20:00	00:35:00	
15	CHP	SCR 7 on CC 40	Slew Right limit stucked	Made it free	00:30:00	00:45:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/09/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 33	OLR acted	Reset	03:30:00	03:40:00	
17	CHP	SCR4 On CC 111	OLR acted	Reset	05:50:00	06:00:00	