



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/09/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCo 10 a	C/S yard side Return core loose	Tightened	05:10:00	05:30:00	
2	CHP	SCR 3 on CC 37	Luff Limit Stuck	Made it free	01:30:00	01:50:00	
3	CHP	SCR 9 on CC 104	LT Drive Tripped	Reset	02:30:00	02:45:00	
4	CHP	SCR 10 on CC 105	HT Breaker was off on the machine	Made it on	00:00:00	01:00:00	
5	CHP	CO 2 ZSS	Cage c clamp problem	Replaced	03:30:00	04:00:00	
6	CHP	CC 131	OLR acted	Reset	01:10:00	01:15:00	
7	CHP	RG3	Temperature Scanner Neutral missing	Tightened	04:15:00	04:25:00	
8	WT	OC 1a	Zss probe damaged	Replaced	01:15:00	01:45:00	