



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/10/2026

Area: WT

Equipment	Job
OP 1 and 2	Trolley line inspection done, found cable puncture @ col 27 in OP 2 ,packing provided
MIS	CISF sump pump handed over @ main fire station
MIS	LC 9 burnt sup pump and one pusher motor sent to ERS
CP 4	AC unit commissioning done
AF 1 and 2 (C)	Earth strips welding done to P J B s
AF 1 to AF 6 (O)	panel blowing done
OP 1 to OP 6	parking zone panels maintenance done