



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/08/2026

Incharge(s): K SANKARA RAO

Shift: C

| Sl No | Area | Equipment | Problem   | Action     | From     | To       | Remarks |
|-------|------|-----------|-----------|------------|----------|----------|---------|
| 1     | OHP  | CO-26     | OLR ACTED | RESET DONE | 00:30:00 | 00:40:00 |         |
| 2     | OHP  | CO-25     | OLR ACTED | RESET DONE | 01:45:00 | 01:55:00 |         |
| 3     | CHP  | CC-54     | OLR ACTED | RESET DONE | 01:00:00 | 01:10:00 |         |
| 4     | IOSA | OC-33A    | OLR ACTED | RESET DONE | 03:10:00 | 03:20:00 |         |