



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/06/2026

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WBR ON CO 6A	INTERLOCK ZSS CAGE PROBLEM	CAGE REPLACED	22:35:00	23:05:00	
2	OHP	CO 25	OLR ACTED	RESET	23:30:00	23:40:00	
3	OHP	CO 33M	OLR ACTED	RESET	02:30:00	02:35:00	
4	OHP	BRC 4 ON CO 8A	TEMPERATURE SENSOR PROBLEM	BYPASSED	04:45:00	05:15:00	
5	CHP	CC 125	OLR ACTED	RESET	05:00:00	05:05:00	
6	CHP	SCR 6 ON CC 104	LT TRACK JAMMING	INFORMED TO OPRN	00:30:00	00:45:00	
7	CHP	SCR 8 ON CC 112 LT	PCRD OLR ACTED	RESET	04:00:00	04:15:00	
8	CHP	SCR 3 ON CO 37	AFTER DNW CLEARANCE	POWER CHARGED	01:00:00	06:00:00	
9	CHP	CC 28	OLR ACTED	RESET	00:30:00	02:15:00	4 TIMES
10	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	23:25:00	02:05:00	3 TIMES
11	CHP	CC 54	OLR ACTED	RESET	23:15:00	23:20:00	
12	CHP	CC 131	R PHASE GOT CUT NEAR INCOMER BUS BAR	PROPERLY JOINT DONE	22:25:00	22:55:00	
13	WT	CP 3	PLC WENT TO STOP MODE	POWER RECYCLED AND BROUGHT TO RUN MODE	23:30:00	00:10:00	