



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 03/10/2026

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	olr acted	reset	23:15:00	23:25:00	3 times
2	OHP	co 26	olr acted	reset	04:15:00	04:25:00	
3	OHP	CO 29	olr acted	RESET	23:15:00	23:25:00	
4	OHP	WOB R ON CO26	slew not working,olr acted	reset	02:50:00	03:02:00	
5	OHP	RSCO9A(b)	olr acted	reset	03:40:00	03:50:00	
6	CHP	CC 58	tripped in curt sp	reset	04:00:00	04:15:00	
7	CHP	cc131	ol acted	reset	00:30:00	00:35:00	2 times
8	CHP	CC 33	scr2 b/w not working,drive tripped	reset	01:30:00	01:45:00	