



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/06/2026

Incharge(s): G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 25	TRIPPED ON OLR	RESET DONE	10:50:00 12:15:00	11:00:00 12:25:00	
2	OHP	SCR 5 ON CC38	LT NOT TAKING PLACE/PCRD CABLE TENSION ACTED	RESET DONE	10:00:00	10:10:00	
3	CHP	CC 51	MPD TRIPPED ON OLR	RESET DONE 3 TIMES	10:50:00	12:20:00	
4	IOSA	TBS ON 14A	C/S ACTING	TEMPORARY BYPASSED AND AFTER INSTRUMENTATION CLEARENCE KEPT INCKT	07:50:00	08:10:00	