



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/09/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	Reported tripped	OLR acted.Reset done	16:50:00 19:05:00 21:00:00	17:00:00 19:15:00 21:10:00	
2	OHP	CO-34	Reported tripped	OLR acted.Reset done	18:55:00 19:00:00 21:22:00	19:00:00 19:05:00 21:28:00	
3	OHP	CO-4A	Reported BRS acted	Sensor problem.Bypassed	15:30:00	15:45:00	To be checked and to be rectified
4	CHP	CC-52	MPD tripped	Reset done	17:35:00	17:40:00	
5	CHP	Cc-131	PC acted	PC switch reset done and found healthy	17:30:00	17:40:00	
6	CHP	CC-130	Reported emergency acted	Emergency PB released and tested okay	17:40:00	18:00:00	
7	CHP	SCR-3 on CC-36	LT not taking place	Drive tripped 5 times.M2 motor disconnected and tested okay	14:40:00	18:45:00	M2 motor to be checked
8	CHP	CC-28 FG	Reported tripped	OLR acted.Reset done	14:30:00	14:34:00	