



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/09/2026

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-85	ZSS acting	Probe replaced and tested okay	16:30:00	17:00:00	
2	OHP	CO-11	ZSS acting	Belt moving slow due to jamming	20:50:00	21:10:00	Informed to operation
3	CHP	CC-53 TT	LT not taking place	Tripped.Reset done	17:00:00	17:10:00	
4	WT	CP-1,3	Not moving	Checked and found modem at walk way bridge not communicating.Replaced with new modem and tested okay	19:00:00	21:10:00	No delay as rakes not there