



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/09/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34	TRIPPED ON OLR/3TIMES	RESET ODNE	00:30:00 00:55:00 23:40:00	00:35:00 01:00:00 23:45:00	
2	OHP	CO 26	TRIPPED ON OLR	RESET DONE	01:00:00	01:05:00	
3	OHP	CO 25	TRIPPED ON OLR	RESET DONE	04:20:00	04:25:00	
4	CHP	CC 58	TRIPPED ON SP FAULT	RESET DONE	23:25:00	23:45:00	
5	CHP	CC 202	PC ACTED	RESET DONE	05:00:00	05:15:00	
6	CHP	CC 201	TRIPPED ON OLR	RESET DONE	04:30:00	04:40:00	
7	WT	CP 3	F/R NOT TAKING PLACE	E-STOP ACTED/RELEASED	04:00:00	04:10:00	