



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/09/2026

Shift: A

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	TRIPPED ON OLR	RESET DONE	10:00:00	10:05:00	
2	OHP	CO 45	REPORTED RED/STOP PB OPERATED	INFORM TO OPERATION	08:45:00	08:55:00	
3	OHP	CO 10A	TRIPPED ON OLR	RESET DONE	11:40:00	11:45:00	
4	OHP	TBS ON CO 5A	NO DRIVES RUNNING/T/F -1 CONTROL SUPPLY TRIPPING.	CONTROL T/F -2 MADE ON AND GIVEN CLEARENCE	07:20:00	07:50:00	
5	OHP	WOBR ON CO 26	LT NOT TAKING PLACE/M2 OLR ACTED	RESET DONE	09:35:00	09:50:00	BREAKE ADJUSTED ALONG WITH MECH.
6	OHP	VF 16A	CHUTE VIBRATOR NOT WORKING/ MOTOR BASE BOLTS LOOSE	INFORM TO G SHIFT	07:45:00	08:00:00	
7	OHP	RSCO 6A	CHUTE VIBRATOR NOT WORKING/Y PHASE GOT CUT IN MOTOR TB	RE-TERMINATION DONE	08:45:00	09:00:00	
8	OHP	TT 4 ON CO 3A	PENDING FROM C SHIFT	TESTED AND GIVEN CLEARENCE	06:00:00	09:10:00	
9	OHP	CO 111	TRIPPED ON MPCB	MADE ON	13:30:00	13:35:00	
10	OHP	BRC 3 ON CO 34	B PHASE MISSING	CHECKED AT SLIPRING, T/F OUT GOING. BREAKER, AND BUS BAR/DIDNT FOUND ANY PROBLEM /POER MADE ON TESTED OK	12:00:00	12:40:00	
11	OHP	BRC 2 ON 28	BC NOT RUNNING/C/S ACTED	SENSOR CLEANING DONE AND RESET	10:40:00	11:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/09/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	SCR 7 ON CC40	LT END LIMIT BYPASS REQUIRED FOR OPE.	BYPASSED AT I/O RACK	11:20:00	11:30:00	
13	CHP	CC 131	TRIPPED ON OLR	RESET DONE	09:15:00	09:20:00	
14	CHP	CC 52	MPD TRIPPED ON OLR/5TIMES	RESET DONE	11:00:00	13:30:00	
15	CHP	CC 51	MPD TRIPPED ON OLR	RESET DONE	11:00:00	11:10:00	
16	WT	OP 5	F/R NOT TAKING PLACE/TOP PAD GOT FALLEN AT COLUM NO 69	TO BE CHANGED	13:40:00	14:00:00	