



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/09/2026

Shift: A

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS-2A	OLR ACTED	RESET DONE	09:45:00	09:50:00	
2	OHP	BRC -ON CO-34	REPORTED B/C NOT RUNNING FOUND PULLY SLIP	INFORMED TO MECHANICAL	08:20:00	08:30:00	
3	OHP	WOBR ON CO-29	REPORTED B/C NOT RUNNING FOUND C/S MODULE PROBLEM	POWER CHECKED AND FOUND OKAY.INFORMED TO OPERATION TO INFORM TO INSTRUMENTATION	09:50:00	10:00:00	
4	CHP	CC-54	OLR ACTED	RESET DONE	07:35:00	07:40:00	
5	CHP	CC-112 SCR-8	REPORTED SLEW NOT WORKING FOUND LOW CHARGE PRESSURE P1 NOT HEALTHY	INFORMED TO MECHANICAL	08:00:00	08:20:00	
6	CHP	CC-39 R-1	REPORTED SLEW NOT WORKING FOUND DRIVE TRIP DUE TO SLEW AREA JAMMING	INFORMED TO OPERATION AND DRIVE RESET DONE	10:40:00	11:00:00	
7	CHP	CC-126	REPORTED NOT RUNNING FOUND CJD ACTED	RESET DONE	12:20:00	12:45:00	