



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/10/2026

Area: WT

Equipment	Job
CP 3	PLC @ pusher ether net cable convertor to POE changed,OK
CP 1	Forward /Reverse indication @ cabin checked and program correction done, OK
OP 3	Trolly line inspection done, found cable puncture packing provided @ col 54
OP 10	Control cable removal done