



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 11/08/2026

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co-32	REPORTED YARD INTERLOCK ZSS CAGE NOT ROTATED FOUND ZSS CAGE STUCK UP WITH STONE	STONE REMOVED THAN OK	00:00:00	00:20:00	
2	OHP	CO-25	OLR ACTED	RESET DONE	00:35:00	00:45:00	
3	OHP	CO-29	OLR ACTED	RESET DONE	04:30:00	04:35:00	
4	OHP	CO-26	OLR ACTED	RESET DONE	04:30:00	04:35:00	
5	CHP	CC-54	MPD TRIP	RESET DONE	05:20:00	05:25:00	
6	CHP	CC-131	OLR ACTED (2TIMES)	RESET DONE	01:35:00 05:20:00	01:45:00 05:30:00	
7	CHP	CC-40 SCR-7	B/C OLR ACTED	RESET DONE	05:20:00	05:30:00	