



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 24/08/2026

Incharge(s): Nagendra Midde,K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	OLR ACTED(2TIMES)	RESET DONE	15:40:00 17:15:00	15:55:00 17:25:00	
2	OHP	CO-26	OLR ACTED	RESET DONE	18:30:00	18:40:00	
3	OHP	BRC ON CO-28	B/C OLR ACTED	RESET DONE	21:10:00	21:15:00	
4	CHP	CC 40	OLR acted	Reset	16:30:00	16:35:00	
5	CHP	CC 52 TIS	Motor Olr acted	Reset	19:30:00	19:40:00	
6	CHP	CC 54	OLR acted	Reset	21:10:00	21:20:00	
7	CHP	CC 115b Brs	Alignment problem	Readjusted	21:00:00	21:30:00	