



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/06/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29	olr acted	reset	15:00:00	15:05:00	
2	OHP	co 25	OLr acted	reset	15:00:00	15:10:00	
3	OHP	BRC on co 28	B/C not running,due to OLR	reset done	19:00:00	19:15:00	
4	OHP	BRC on co 30	LT not working,drive tripped in overcurrent	reset	18:45:00	18:55:00	
5	CHP	CC 51	MPD tripped 2 times	reset	20:00:00	20:05:00	
6	CHP	CC 131	motor tripped on overload	reset	21:05:00	21:10:00	
7	CHP	CC 112 SCR8	B/C not running	wrong complaint	16:30:00	16:40:00	
8	CHP	CC 44	MPD acted	reset	20:40:00	20:45:00	
9	CHP	CC 37 SCR3	LUff not working,oil level low	informed mechanical	21:20:00	21:25:00	
10	WT	OAF1A,2A and OC1A	not healthy,	PLC power recycle done	18:00:00	18:15:00	
11	IOSA	L and T wob	LT NOT WORKING,PCRD OT acted	OT released	15:35:00	15:50:00	