



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/05/2026

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	15:35:00	16:50:00	2 TIMES
2	OHP	CC 201	OLR ACTED	RESET	16:35:00	16:40:00	
3	OHP	TT4 NOT MOVING	MPCB TRIP	MADE IT ON	20:25:00	20:35:00	
4	OHP	CO 3A	MECH BRS SENSOR TO STRIKER GAP	ADJUSTMENT DONE	20:25:00	20:35:00	
5	CHP	SCR 6 ON CC 40 LT	M2 TRIP	RESET	16:50:00	17:00:00	
6	CHP	SCR 1 ON CC 31 SLEW	DRIVE TRIP	RESET	18:15:00	18:25:00	
7	CHP	SCR 5 ON CC 38 LT	LOCAL EMERGENCY STOP NOT RELEASED	RELEASED	21:10:00	21:20:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	18:00:00	19:30:00	2 TIMES
9	WT	AF 6	DRIVE TRIP	RESET	20:30:00	20:50:00	