



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/05/2026

Area: CHP

Equipment	Job
CC 115	3 nos 35W LED fixtures provided
CM 27,28	RIO panels door opening closed
SCR 8,R 1	9 nos 30W LED fixtures replaced and 5 nos tube fixtures replace
CC 8, CC 41 tunnel blower	Burnt motor sent to ERS
HT IC 1 and 6	Maintenance was done