



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/08/2026

Incharge(s): P Venkat Kiran,P Venkat Kiran

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC-2 on CO-30	shifted from CO-30 to CO-31	shifted from CO-30 to CO-31	10:00:00	12:00:00	
2	OHP	CO-14B TO CO 20 CV	R PHASE LOOSE	FIXED PROPERLY	07:45:00	08:05:00	
3	OHP	RSCO-6A	TRIPPED	RESET DONE	12:00:00	12:15:00	
4	OHP	CO-26	TRIPPED ON OLR	RESET DONE	09:20:00 12:43:00	09:30:00 12:50:00	
5	CHP	CC-33 SCR-2	SLEW DRIVE TRIPPED	RESET DONE	09:30:00	09:45:00	
6	CHP	CC-131	TRIPPED 3 TIMES	RESET	10:40:00	13:15:00	