



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/09/2026

Area: CHP

Equipment	Job
CC 132, RG EOT	PPM was done
SCR 5	Instrumentation sensors maintenance done
CC 222/223 Gallary	10 nos 70W SV fixtures provided
CC 32	Removed motor coupling removed and sent to ERS for overhauling
CM 18	Rooms cleaning done
CC 32	Motor replaced and trail run was taken
CC 13	Running inspection defect rectified
CC 13, 27, 27A, TT	PPM was done