



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/05/2026

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment         | Problem                                          | Action                 | From                 | To                   | Remarks                                                 |
|-------|------|-------------------|--------------------------------------------------|------------------------|----------------------|----------------------|---------------------------------------------------------|
| 1     | OHP  | CO16              | OLR ACTING FREQUENTLY DUE TO DECK SHEETS JAMMING | INFORMED OPRN TO CLEAN | 17:30:00             | 20:30:00             | 4 TIMES                                                 |
| 2     | OHP  | CO 26             | OLR ACTED                                        | RESET                  | 15:45:00<br>20:45:00 | 15:55:00<br>21:00:00 |                                                         |
| 3     | OHP  | TBS ON CO 5A      | LBC OLR ACTED                                    | RESET                  | 18:50:00             | 19:10:00             |                                                         |
| 4     | CHP  | CC 51             | FEEDING CONV OLR ACTED                           | RESET                  | 14:20:00             | 21:25:00             | 2 TIMES                                                 |
| 5     | CHP  | CC 54             | OLR ACTED                                        | RESET                  | 15:35:00             | 15:40:00             |                                                         |
| 6     | CHP  | SCR 4 ON CC 32 LT | O/T ACTED                                        | RELEASED               | 16:25:00             | 16:35:00             |                                                         |
| 7     | CHP  | SCR 1 ON CC 31 LT | PCRD CABLE ZIG ZAG                               | WINDING DONE PROPERLY  | 18:00:00             | 18:20:00             |                                                         |
| 8     | CHP  | CC 49 ZSS ACTING  | CJB TO ZSS MODULE CABLE PROBLEM                  | BYPASSED               | 17:30:00             | 18:00:00             | CABLE MULTIPLE JOINTS OPENED AND CHECKING UNDER PROCESS |
| 9     | WT   | OP5               | D5 TRIPPED                                       | RESET                  | 18:30:00             | 18:50:00             |                                                         |
| 10    | WT   | OP1               | D 5 TRIP                                         | RESET                  | 20:00:00             | 20:20:00             |                                                         |
| 11    | WT   | OT 3              | D2 TRIPPED                                       | RESET                  | 21:00:00             | 21:05:00             |                                                         |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 11/05/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem                   | Action     | From     | To       | Remarks |
|-------|------|-----------|---------------------------|------------|----------|----------|---------|
| 12    | WT   | CP 2      | BREAKER TRIPPED IN LC 10A | MADE IT ON | 19:30:00 | 19:40:00 |         |