



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/07/2026

Shift: C

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	VS 3A	TRIPPED ON OLR	RESET DONE	05:10:00	05:20:00	
2	OHP	CO 8	HEALTHY STOP WHILE RUNNING/LOOSE AT SOFT RELAY TERMISSION	TIGHTENED	02:05:00	02:05:00	
3	OHP	TBS ON CO 21	LT NOT TAKING PLACE/PCRD CABLE TENSION ACTED	TENSION RELEASED	23:25:00	23:40:00	
4	OHP	BRC ON CO 30	LT NOT TAKING PLACE/DRIVE TRIPPED	RESET DONE	23:40:00	23:55:00	
5	OHP	WOBR ON CO 6A	NO DRIVES RUNNING/ACB TRIPPED	ACB MADE ON	01:25:00	01:45:00	
6	OHP	TBS ON CO 21	LT NOT RUNNING/SELECTOR IN LOCAL MODE	KEPT IN REMOTE MODE	02:08:00	02:15:00	
7	OHP	CO 84	BRS ACTED/(JOD)	RESET DONE	04:00:00	04:15:00	
8	CHP	TT ON CC58	LT NOT TAKING PLACE/OLR ACTED	RESET DONE	03:40:00	04:00:00	
9	CHP	CC 48	ZSS ACTING/CAGE BEARINGS PROBLEM	ZSS CAGE REPLACED	22:00:00	22:45:00	
10	CHP	SCR 9 ON CC213	BW NOT RUNNING/MCCB TRIPPED	MCCB MADE ON	02:45:00	02:55:00	
11	CHP	SCR 7 ON CC 40	BC NOT RUNNING/OLR ACTED	RESET DONE	02:50:00	03:05:00	
12	CHP	SCR 7 ON CC40	SLEW NOT TAKING PLACE/30 DEGREE LIMIT ACTED	RESET DONE	03:25:00	03:40:00	
13	CHP	SCR 2 ON CC33	BC NOT RUNNING	DIDNT FOUND ANY PROBLEM TESTD OK	00:50:00	01:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/07/2026

Incharge(s): G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP 5	F/R NOT TAKING PLACE/D 5 TRIPPED ON OLR WHILE COUPLING	RESET DONE	23:30:00	23:40:00	